



# GENERAL NOTES:

1. FOR INSTALLATION IN ROADWAYS, DRIVEWAYS, SIDEWALKS, OR PARKING AREAS PRIOR APPROVAL REQUIRED. ROAD LID MAY BE REQUIRED.
2. NO CONCRETE FLOOR ALLOWED IN METER PIT.
3. ACCORDING TO SECTION 6.27, METER PIT SHALL BE CONSTRUCTED OF ANY COMBINATION OF CONCRETE RINGS TOTAL-48\"
4. ADJUSTMENT RINGS OF APPROVED PLASTIC & CONCRETE SHALL BE 2\",3\",4\", OR 6\" IN HEIGHT AND SHALL BE INSERTED BETWEEN THE DOME AND TOP RING.
5. NO CONNECTIONS OR CHANGES IN PIPE DIAMETER SHALL BE MADE IN THE METER PIT OR IN THE DISTANCE OF FIVE FEET BEYOND THE METER. PIT WALL ON THE OUTLET SIDE, EXCEPT WHEN NECESSARY TO COMPLY WITH SECTION 6.15.
6. LAWN SPRINKLER CONNECTIONS SHALL BE A MINIMUM OF FIVE FEET FROM THE METER PIT WALL ON THE OUTLET SIDE.
7. ALTERNATIVE TO CONCRETE IS AN APPROVED ONE PIECE PLASTIC METER PIT.
8. METERS REQUIRE AN ELECTRONIC DIGITAL ENCODER OR MECHANICALLY ENCODED REGISTER WITH AN ITRON ERT MODEL 40W-1.

METER SIZE	A	B	C	D
3/4"	14 1/4"	9 5/16"	8 15/16"	5"
1"	17 1/4"	11 1/16"	11 1/4"	6"

## DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204  
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

## OUTSIDE SETTING FOR 3/4\" & 1\" METERS

Scale:   NONE   Date:   AUGUST 1995  

Drawn:   C.B.B.   Tr:            Ck:           

Approved:                    Dr.   127   No.   35